



30105 Beverly Road
 Romulus, MI 48174
 Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

Client : Bay Hill Environmental
 712 Dover St
 Cherry Hill, NJ 08002
Attn : Bill ODonnell **Email :** bayhillenvironmental@comcast.net
Phone : 609 238-3012 **Fax :**
AAT Project : 483480
Sampling Date : 04/15/2019
Date Received : 04/16/2019
Date Analyzed : 04/18/2019
Date Reported : 4/18/2019 4:12:42PM
Client Project : 1023 CALLOWHILL ST 19123 F **Collected By:** **WSSN :**
Project Location : 1023 CALLOWHILL ST 19123 FACTS CHARTER SCHOOL

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead µg/L (ppb)	Reporting Limit	Pb Threshold
4650335	1	EXTERIOR WATER FOUNTAIN *			10.2	1.0	Below
4650336	2	2ND FL NURSE BATHROOM SI			1.1	1.0	Below
4650337	3	2ND FL WATER FOUNTAIN			1.2	1.0	Below
4650338	4	3RD FL WATER FOUNTAIN			<1.0	1.0	Below
4650339	5	3RD FL KITCHEN SINK			<1.0	1.0	Below
4650340	6	4TH FL WATER FOUNTAIN			<1.0	1.0	Below
4650341	7	4TH FL TEACHER LOUNGE SIN			1.1	1.0	Below
4650342	8	5TH FL WATER FOUNTAIN			<1.0	1.0	Below
4650343	9	5TH FL GIRLS BATHROOM SIN			1.1	1.0	Below
4650344	10	2ND FL KINDERGATEN BATHR			2.1	1.0	Below

Analyst Signature

Robert Limmer

* NOTE FROM FACT CHARTER SCHOOL
 THIS EXTERIOR FOUNTAIN HAS BEEN DECOMMISSIONED (NO SPOT, NO KNOB).
 IT IS NOT BEING USED AS A DRINKING FOUNTAIN. IT HAD BEEN
 DECOMMISSIONED PRIOR TO THIS TESTING.

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 1.0 µg/L (ppb) and for Cu is 1.5 µg/L (ppb).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.

EPA Regulatory Limits: 15 µg/L for Pb and 1300 µg/L for Cu

The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted.

All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 30 days following report date.

